


TEST REPORT

No. : CZIN2303000030CM

Date: Mar 27, 2023

Page: 4 of 4

Frequency Hz	Absorption Coefficient, α_s
100	0.12
125	0.23
160	0.21
200	0.43
250	0.52
315	0.58
400	0.76
500	0.89
630	0.95
800	0.98
1000	1.02
1250	0.91
1600	0.79
2000	0.82
2500	0.94
3150	0.94
4000	0.97
5000	1.00
$\bar{\alpha}_s$	0.73
NRC	0.80



Note: This declaration of conformity is only based on the result of this laboratory activity, the impact of the uncertainty of the results was not included.

***** End of report*****